



This drawing is to be read in conjunction with the manufacturer's installation recommendations

ACO StormBrixx tank piece 1200X600X610mm (H) Brick or Cross Bonded part Number 314020

Roadbase material and depths to suit engineer's specification. Min cover to be in accordance with Table A



NOTE:
Top covers part Number 314022 shown below to be installed on top layer of StormBrixx Modules only.



DR R.HILL


Minimum cover depths (1) over the top of ACO StormBrixx		Minimum cover depth (m) (4)
Location		
Non-Trafficked areas i.e. Landscaping		0.5 (2)
Car parks, vehicle up to 2500kg gross mass		0.6
Car parks, occasional vehicle greater than 2500kg (3) gross mass		0.8
Occasional HGV traffic up to 44000kg GVW (HA loading)		Please consult with ACO

(1) Assumes 27 degree load distribution through fill material and overlaying surface asphalt or block paving
(2) Minimum cover depth to avoid accidental damage from gardening/landscaping work
(3) Occasional Trafficking by refuse collection or similar vehicles (typically one per week)
(4) Please check minimum frost cover depths for geographical location

Scale:

N/A @ A3

Projection: ISO-E



Unit: mm



Information contained in this drawing is a copyright property of ACO Technologies. Any reproduction in part or whole without written permission of ACO Technologies is prohibited.

Date	Name	Checked by
Drawn 14.11.11	RS	NR
Updated 16.11.11	RS	NR

Drawing No.

E1-E01-071-3

Issue A

Title: ACO STORMBRIX ATTENUATION Trafficked area (On-line)