


Installation manual

ACO Sludge Trap G-H



CONTENT



CONTENT	2
STRUCTURE AND COMPONENTS	3
INSTALLATION IN GENERAL	4
Application	
Proper use includes	
Staff	
Journal	
Technical Amendments	
Product Despriction	
Function	
Flexible application	
STRUCTURE - A 15/B 125/D 400	5
DIMENSIONS - A 15/B 125/D 400	6
LEGEND	7
TANK INSTALLATION	7
TOP SECTION INSTALLATION	10
ALARM CONNECTION	12
TOP SECTION INSTALLATION FOR LOAD CLASS - A 15/B 125/D 400	12
DESIGNATION LABEL	16
NOTES	17

Note:

Read this manual before installing the Sludge Trap G-H This manual is for the ACO prefabricated Sludge Trap G-H.

This manual should be used when installing the Sludge Trap G-H. This manual should be kept available at the workplace / installation site. Installation of the Sludge Trap G-H must be performed by qualified installers.

Provisions under applicable laws should be followed in order to prevent accidents and protect the environment.

Terms and Conditions:


Any change or alteration made to the Sludge Trap G-H by the consumer without ACO's specific approval will void all warranty obligations.

STRUCTURES AND COMPONENTS



ACO Sludge Trap G-H A 15

- A Grease Separator (bottom part)
- B Extension shaft
- C ACO Cover A 15
- D Inlet
- E Outlet
- F Slot for alarm connection (optional)



ACO Sludge Trap G-H B 125 / D 400

- Grease Separator (bottom part)
- B Extension shaft
- C ACO Cover B 125 / D 400 and load protection slab
- D Inlet
- E Outlet
- F Slot for alarm connection (optional)
- G Concrete load distribution plate

INSTALLATION IN GENERAL

Application

The Sand Trap G-H is a tank designed for the removal of gravel and silt from stormwater and wastewater. Wastewater, for example, comes from the car wash, garage, parking areas or industries.

The manufacturer is not liable for any damages caused by misuse. Responsibility falls entirely on the operator.

Terms and Conditions:

- Compliance with national laws and regulations;
- Compliance with all inspection and service instructions;
- Adhere to the manufacturer's installation, operation and maintenance instructions.

Staff

Personnel who perform the installation, operation, maintenance and servicing of this sludge separator must possess the training needed to do these tasks and must understand the contents of this manual.

Journal

A record shall be established and include the following:

- Checks carried out by operaonal staff;
- Service and test reports;
- Any breakdowns and repairs.

Technical Amendments

ACO reserves the right to make ongoing technical modifications which may result in differences between published text and/or images, and the product.

Product Descripon

The Sand Trap G-H gravel and silt separator is designed for installation in the ground. The separator comes with inlet and outlet connections, an extension neck made of PE-HD.

Function

Sand Trap G works on the gravimetric principle. Sludge and heavier particles fall to the bottom. The treated water flows out through the outlet.

Flexible application

(according to EN 124)

Load classes

A 15

Footways and areas accessible only to pedestrian & pedal cyclists

B 125

Footways that can be mounted by vehicle or livestock, and light tractor paths

D 400

Carriageways of roads and areas open to commercial wehicles

Load classes








B 125




D 400


STRUCTURE - A 15



STRUCTURE - B 125 / D 400




DIMENSIONS - A 15



SIZE	A 15 - T to	-
	MIN	MAX
Short	520	640
Medium	520	1090
Long	520	1690

DIMENSIONS - B 125 / D 400



SIZE	B 125 - T top section MIN MAX	
Short	550	670
Medium	550	1120
Long	550	1720


SIZE	D 400 - T top section		
OILL	MIN	MAX	
Short	550	655	
Medium	550	1130	
Long	550	1730	

LEGEND


LEGEND - LAYERS			
	Soil		
	Compacted soil		
	Gravel 2 - 8 mm		
	Gravel 8 - 16 mm		
	Sand		
	Water		
	Final surface		


SAND / GRAVEL 8-16 mm					
Table (CE/3 Packing Tool	Layer Thickness	Passes / Layers		
	Hand stamp min. 15 kg	150 mm	4		
Ţ	Vibrator stamp 70 kg	300 mm	4		
£	Vibrator flat 100 kg	150 mm	6		


TANK INSTALLATION




TANK INSTALLATION











Final surface

9


TANK INSTALLATION





TOP SECTION INSTALLATION



TOP SECTION INSTALLATION










11


ALARM CONNECTION



TOP SECTION INSTALLATION FOR LOAD CLASS - A 15









13

Compacted soil

TOP SECTION INSTALLATION FOR LOAD CLASS - B 125 / D 400







Final surface


Gravel 8 - 16 mm

Compacted soil






TOP SECTION INSTALLATION FOR LOAD CLASS - B 125 / D 400



DESIGNATION LABEL



NOTES



Final surface

Water

Sand


May 8 - C leve

Compacted soil


Soil

17 ||||

NOTES



NOTES



ACO Industries Tábor s.r.o.

Prumyslova 1158 391 01 Sezimovo Usti Czech Republic

www.aco.com

ACO. The future of drainage

All reasonable care has been taken in compiling the information in this document. All recommendations and suggestions on the use of ACO products are made without guarantee since the conditions of use are beyond the control of the Company. It is the customer's responsibility to ensure that each product is fit for its intended purpose and that the actual conditions of use are suitable. This brochure and any advice is provided free of charge and accordingly on terms that no liability (including liability for negligence) will attach the Company or its servants or agents arising out of or in connection with or in relation to this brochure or any such advice. Any goods supplied by the Company will be supplied solely upon its standard conditions of sale, copies of which are available on request. The Company's policy of continuous product development and improvement renders specifications liable to modification. Information provided in this brochure is therefore subject to change without prior notification.

ACO GRP Sludge Trap G-H/En/04/17/JMa/ Subject to technical changes without notice.